



ADDENDUM NO. 1
Issued April 30, 2008

TO

“REQUEST FOR BIDS
FOR
INSPECTION AND MAINTENANCE OF THE
SHELTON LANDFILL ASH LEACHATE
COLLECTION AND TREATMENT SYSTEM”
(Bid Number FY08-EN-008
(RFB Issued April 9, 2008)

Note: Proposers are required to acknowledge this and all Addenda in Section 3.2(a) of the Bid Form.

This Addendum consists of the Connecticut Resources Recovery Authority’s (CRRA) responses to questions that were raised at the pre-bid conference and site tour on April 8, 2008 and to questions that were submitted in writing to CRRA by April 24, 2008, the deadline for questions specified in the RFB Package Documents. Attached to the Addendum is a list of the individuals that attended the pre-bid conference and site tour.

1.	Question	In section 5(d) of the Instructions To Bidder, the text indicates that Services include preparation and submission of monthly, semi-annual and annual inspection reports. However, there do not appear to be any monthly requirements the “Routine Inspection & Maintenance Checklist.”
	Answer	In section 5(d) of the Instruction To Bidders, reference to “monthly” is changed to “quarterly.”

2.	Question	What is expected of the annual performance of the cathodic protection system inspection and maintenance of the leachate storage tank?
	Answer	The successful bidder must subcontract to Northeast Tank for the annual inspection and maintenance of the cathodic protection system for the leachate storage tank. CRRA has a warranty from Northeast Tank for the cathodic protection system, which is why Northeast Tank must perform the annual inspection and maintenance.
3.	Question	With regard to solids that may be created/discovered in the annual cleaning of the pH adjustment tank, how should they be managed?
	Answer	The successful bidder must on its own if properly permitted or through a subcontract with a properly permitted firm, remove and dispose of any solids created and/or discovered during the annual cleaning of the pH adjustment tank.